

SKY'S THE LIMIT ENTERTAINMENT

RISK ASSESSMENT - Generator (Petrol)

Revised: 24 March 2025 Author: R. Hanlon

Hazard	Risk	Existing Controls	Likelihood 1 - 5	Severity 1 - 5	Risk Score 1 - 5	Further Action
Generator	Unauthorised tampering	Designated person (+18yrs) to supervise at all times Safety barrier to fully surround generator	2	1	1	If event has a large attendance or extended run times more designated persons may have to be allocated
Generator	Fuel	Generator supplied with full tank (Petrol) Any subsequent filling to be done with engine off by the designated person Leave 3mins before refilling	1	2	3	No fuel should be stored near generator. Lock any fuels away from public areas
Generator	Burns	Safety barrier to surround generator Do not touch exhaust / engine area	1	2	2	Spectators must be well clear of the generator
Generator	Adverse weather	All voltage outlets are outdoor use type	2	1	1	None
Generator	Fire	Do not approach the generator Do not attempt to extinguish yourself Dial 999 and ask for fire service Evacuate surrounding area to a safe distance	1	3	3	None
Generator	Location	Position generator away from trees and other flammable areas Not to be used indoors or within a contained area Make sure any exhaust fumes are freely dissipated	1	1	1	Generator should be on level ground
Generator	General	There are no user checks - all checks are done pre-delivery Any concerns should be addressed to the supplier, call mobile number available on issued paperwork / website	1	1	1	None
Generator	Injury	Seek First aid or dial 999 Report injury to supplier	1	1	1	